Project _____ Catalogue n° _ Туре _____ Паte

AimLite

CARPW ALUMINUM COMBO NBC2015 COMPLIANT

The CARPW series of commercial combination extruded signs and battery units features a fully modern appearance. The extruded aluminum design provides for a rigid, durable and lightweight sign. Two PAR18 small style, front mounted heads are standard, MR16 type are optional. Available with either 6 V DC or 12 V DC.



FEATURES & SPECIFICATIONS

CIRCUITRY

- LED ultra bright light source
- 120/347 V AC field selectable, or 277 V AC
- 1.8 W power consumption for LED exit portion of combination sign
- LED Emergency DC wattages as follows:
 6 V DC = 0.9 W
 12 V DC = 0.86 W
- Wattage capacities from 36 to 72 W
- 30 minutes emergency power duration standard

- Momentary push button test switch
- Pilot LEDs for AC ON and CHARGE
- Fully automatic, constant voltage current limited charger
- Solid state design and construction with brownout and short circuit protection
- Temperature compensatedMaintenance free, sealed
- lead acid battery

MECHANICAL

- Extruded aluminum construction
- Slide in/out captive faceplate(s) and backplate for rapid and simplified installation
- Universal spider knockout pattern stamped into backplate for junction box mounting
- Universal models include ceiling or end mount, field installable canopy kit c/w spider plate

- Multiple conduit entry knockouts
- White powder coat finish standard, other finishes and colors optional
- Front head mounted is standard, side mount

is optional

COMPLIANCES


- CSA Certified to C22.2 #141-15
- CSA Certified to C860-11
- Meets requirements of ICES-005

OVERVIEW			
LIGHT SOURCE	LED	SIGN DC VOLTAGE/WATTAGE	6 V DC = 0.9 12 V DC = 0.86
INPUT VOLTAGE (V AC)	120/347, 277	OUTPUT VOLTS (V DC)	6, 12
SIGN POWER CONSOMPTION	120 V = 1.80 W 347 V = 1.70 W 277 V = 1.40 W	POWER CAPACITY [W]	36 - 72
LED ICES	Energy Verified Energie Verifiee		

For complete warranty details, please see our terms and conditions on our website.

Data is based upon tests performed in a controlled environment. Actual performance can vary depending on operating conditions. All products are subject to change or may be discontinued any time without notice.

TYPICAL SPECIFICATION



TYPICAL SPECIFICATION

Supply and install Aimlite's Extruded CARPW Running Man and Battery combination unit. The sign shall be Extruded Aluminum Running Man Exit Signs. The sign shall operate with AC/DC field selectable 120/277/347 V AC. The face shall be illuminated by using Nichia LED ultra-bright light source. The sign shall be suitable for wall, end, or ceiling mount and come complete with 3 Running Man fibers for universal direction. The sign shall be CSA C22.2 141-15 and ICES complaint. The battery unit shall be rated 120 V, 277 V or 347 V, 60 Hz constructed of durable 18-gauge steel and be CSA listed to C22.2 141-15 and be ICES 005 compliant. The unit shall have an output of: ___V and ___W and come complete with (0), (1) or (2) x ___ W LED heads producing [__] lumens each. The charge voltage factory set to ± 1% tolerance. High efficiency, rapid recovery, precision control charging system shall be employed to promote long battery life and reduce the potential for grid corrosion. The charger shall provide a continuous high charge to recharge the battery, when the battery is at full capacity, the charger will shut-off. Periodically the charger shall provide a pulse of energy to keep the battery at full voltage. The pulse charger shall be precisely regulated and shall charge the battery in relation to its temperature, state or charge and input voltage fluctuations. The charger shall be current limited, temperature compensated, short-circuit proof and reverse polarity protected. The unit shall be furnished with an electronic lockout circuit, which will connect the battery when the AC circuit is activated, and an electronic brownout circuit, which will activate the emergency lights when utility power dips below 75% of nominal voltage. A low voltage battery protection circuit shall be provided and will disconnect the load when the battery reaches the end of discharge.

The Aimlite Sign and Battery combination unit shall be CARPW ____

ORDERING GUIDE

CARPW			-	_				/	/
SERIES	WATTS (W)	NBR OF FACES	MOUNTING	NBR OF HEADS	HEAD/LAMP	LAMP	UTH UN	INPUT VOLTAGE (V AC)	OPTIONS
CARPW	036 - 36 050 - 50	1 - SINGLE FACE 2 - DOUBLE	VER-	00 - NO HEADS	BLANK - NO HEADS		WHT - WHITE BLK - BLACK GRY - GREY	BLANK - 120/347 277 - 277	ATD, AUD¹, AUE, LPD, RDS, SMH, TDL¹
	036 - 36 050 - 50 072 - 72	FACE		HEADS	LG - PAR36	BELOW			D - NO INDICATORS (DOUBLE FACE ONLY) ♥ ↑ 7 ≥ K K D U UR OR DL UL

¹Only available with ATD.

OPTIONS

	DESCRIPTION		DESCRIPTION
ATD	AUTOMATIC TEST SELF-DIAGNOSTIC	RDS	RADIO FREQUENCY SUPPRESSION
AUD	AUDIBLE ALARM	SMH	SIDE MOUNTED HEADS
AUE	AUDIBLE EMERGENCY	TDL	TIME DELAY
LPD	LAMP DISCONNECT (INTERNAL)		

LAMP SELECTION

	6 V	12 V
PAR18 - Small head		
LED	3WLJ, 4WLJ, 5WLJ	3WLJ, 4WLJ, 5WLJ, 6WLA, 7WLA
Tungsten	09WT	09WT
MR16 - Small head c/	w MR16	
LED	4WLR, 5WLA	4WLR, 5WLA, 6WLA, 7WLA

LUMEN TABLE

WATTS	LUMENS
3W LJ	313
4W LJ	388
5W LJ	590
4W LR	388
5W LA	435
6W LA	507
7W LA	652

MODEL RATINGS

MODEL	VOLTS	WATTAGE CAPACITIES (W)			
	(V)	30 MIN.	60 MIN.	90 MIN.	120 MIN.
CARPW0636		36	18	12	9
CARPW0650	6	50	25	16	12
CARPW1236		36	18	12	9
CARPW1250	12	50	25	16	12
CARPW1272		72	36	24	18

LEXAN GUARD


	PART NUMBER	DIMENSIONS (IN)
WALL MOUNT	PGD111	19.75 X 14 X 8
CEILING MOUNT	PGD100	16 X 10 X 13.5


WIREGUARD¹

		PART NUMBER	DIMENSIONS (IN)
	WALL MOUNT	WGD590-V2	16.75 X 17.75 X 6.5
WITHOUT	CEILING MOUNT	WGD650-V2	17.75 X 17.75 X 16.50
	END MOUNT	WGD650-V2	17.75 X 17.75 X 16.50
	WALL MOUNT	WGD510-V2	19.75 X 19.75 X 7.25
WITH HEAD(S)	CEILING MOUNT	WGD650-V2	17.75 X 17.75 X 16.50
	END MOUNT	WGD650-V2	17.75 X 17.75 X 16.50

¹ Please contact your AimLite customer service representative for more information.


DIMENSIONS











TYPE SM - PAR18 Thermoplastic

TYPE MD - MR16 Die cast

TYPE MB - MR16 Die cast

CONFIGURATIONS



Comes standard (single face) with three pictogram legends for direction selection.






PHOTOMETRIC DATA¹

PAR18-06-12V3WLJ • 3<u>09.0 LM</u>

POLAR CANDELA DISTRIBUTION



ZONAL LUMEN SUMMARY

ZONE	LUMENS	% FIXTURE
0-30	282.9	91.6%
0-40	297.5	96.3%
0-60	306.9	99.3%
60-90	2.1	0.7%
70-100	0.3	0.1%
90-120	0	0%
0-90	309.0	100%
90-180	0	0%
0-180	309.0	100%

ILLUMINANCE AT A DISTANCE


CENT	ER BEAM FC		BEAM WIDTH		
1.7'	622		0.6'		
3.3'	165		1.1'		
5.0	71.8		1.7'		
6.7	40.0		2.3'		
8.3	26.1		2.8'		
10.0	18.0		3.4'		
🔳 Be	Beam. Spread: 19.3°				

¹ Complete IES files available on our website.

PHOTOMETRIC DATA¹

PAR18-06-12V4WLJ • 429.5 LM

POLAR CANDELA DISTRIBUTION



ZONAL LUMEN SUMMARY


ZONE	LUMENS	% FIXTURE
0-30	325.3	75.7%
0-40	369.4	86%
0-60	410.4	95.5%
60-90	19.2	4.5%
0-90	429.5	100%

ILLUMINANCE AT A DISTANCE

CENT	ER BEAM FC		BEAM	VIDTH	
1.7'	402		0.8'	8.2'	
3.3'	107		1.6'	16.4'	
5.0	46.4		2.4'	24.6'	
6.7	25.9		3.2'	32.8'	
8.3	16.9		3.9'	41.0'	
10.0	11.6		4.7'	49.2'	
Ve	Vert. Spread: 26.6° Hor. Spread: 27.1°				

PAR18-06-12V5WLJ • 655.3 LM

POLAR CANDELA DISTRIBUTION



ZONAL LUMEN SUMMARY


ZONE	LUMENS	% FIXTURE
0-30	515.6	78.7%
0-40	595.7	90.9%
0-60	637.2	97.2%
60-90	18.0	2.8%
0-90	655.3	100%

ILLUMINANCE AT A DISTANCE

CENT	ER BEAM FC		BEAM	WIDTH	
1.7'	396		0.9'	0.9'	
3.3'	105		1.7'	1.7'	
5.0	45.8		2.5'	2.6'	
6.7	25.5		3.4'	3.5'	
8.3	16.6		4.2'	4.3'	
10.0	11.5		5.1'	5.2'	
🔳 Ve	Vert. Spread: 28.6° 📕 Hor. Spread: 29.4°				

MR16-06-24V4WLR • 228.7 LM

POLAR CANDELA DISTRIBUTION



¹ Complete IES files available on our website.

ZONAL LUMEN SUMMARY

ZONE	LUMENS	% FIXTURE
0-30	164.4	71.9%
0-40	182.0	79.6%
0-60	214.8	93.9%
60-90	13.9	6.1%
70-100	4.1	1.8%
90-120	0	0%
0-90	228.7	100%
90-180	0	0%
0-180	228.7	100%


ILLUMINANCE AT A DISTANCE

CENT	ER BEAM FC		BEAM WIDTH
1.7'	168		1.1'
3.3'	44.5		2.1'
5.0	19.4		3.2'
6.7	10.8		4.3'
8.3	7.04		5.3'
10.0	4.85		6.4'
Beam. Spread: 35.4°			

PHOTOMETRIC DATA¹

MR16-06-24V5WLA • 440.7 LM

POLAR CANDELA DISTRIBUTION



ZONAL LUMEN SUMMARY


ZONE	LUMENS	% FIXTURE
0-30	352.6	80%
0-40	391.8	88.9%
0-60	427.2	96.9%
60-90	13.5	3.1%
70-100	4.3	1%
90-120	0	0%
0-90	440.7	100%
90-180	0	0%
0-180	440.7	100%

ILLUMINANCE AT A DISTANCE

CENT	ER BEAM FC		BEAM	WIDTH
1.7'	407		0.9'	1.0'
3.3'	108		1.7'	1.9'
5.0	47.0		2.6'	2.8'
6.7	26.2		3.5'	3.8'
8.3	17.1		4.3'	4.7'
10.0	11.8		5.2'	5.7'
Ve	Vert. Spread: 29.3° 📕 Hor. Spread: 31.7°			

MR16-12-24V6WLA • 508.7 LM

POLAR CANDELA DISTRIBUTION



ZONAL LUMEN SUMMARY


ZONE	LUMENS	% FIXTURE
0-30	407.0	80%
0-40	452.3	88.9%
0-60	493.1	96.9%
60-90	15.6	3.1%
70-100	4.9	1%
90-120	0	0%
0-90	508.7	100%
90-180	٥	0%
0-180	508.7	100%

ILLUMINANCE AT A DISTANCE

CENT	ER BEAM FC		BEAM	WIDTH	
1.7'	470		0.9'	1.0'	
3.3'	125		1.7'	1.9'	
5.0	54.3		2.6'	2.8'	
6.7	30.2		3.5'	3.8'	
8.3	19.7		4.3'	4.7'	
10.0	13.6		5.2'	5.7'	
Ve	Vert. Spread: 29.3° 📕 Hor. Spread: 31.7°				

MR16-06-24V7WLA • 635.2 LM

POLAR CANDELA DISTRIBUTION



¹ Complete IES files available on our website.

ZONAL LUMEN SUMMARY

ZONE	LUMENS	% FIXTURE
0-30	508.2	80%
0-40	564.7	88.9%
0-60	615.7	96.9%
60-90	19.5	3.1%
70-100	6.1	1%
90-120	0	0%
0-90	635.2	100%
90-180	0	0%
0-180	635.2	100%

ILLUMINANCE AT A DISTANCE

CENT	ER BEAM FC		BEAM	WIDTH
1.7'	587		0.9'	1.0'
3.3'	156		1.7'	1.9'
5.0	67.8		2.6'	2.8'
6.7	37.8		3.5'	3.8'
8.3	24.6		4.3'	4.7'
10.0	16.9		16.9'	5.7'
Ve	Vert. Spread: 29.3° 📕 Hor. Spread: 31.7°			